

Sewer Main

Milwaukee Water Works

2

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 6/1/2016
 Type of work: Sewer Main Replacement
 Date work performed: 4/27/16

	Samples Collected Before Work Was Performed	Samples Collected 1 Day After Work Was Performed	Samples Collected 2 Weeks After Work Was Performed	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 4/9/16	Date Sample Collected: 4/28/16	Date Sample Collected: 5/11/16	Date Sample Collected: 5/25/16
Sample 1	Not detected	13 µg/L	Not detected	2.0 µg/L
Sample 2	3.7 µg/L	2.2 µg/L	2.3 µg/L	3.2 µg/L
Sample 3	2.2 µg/L	2.4 µg/L	2.3 µg/L	4.3 µg/L
Sample 4	Not detected	Not detected	2.2 µg/L	5.7 µg/L
Sample 5	4.2 µg/L	Not detected	3.1 µg/L	11 µg/L
Sample 6	4.9 µg/L	Not detected	5.0 µg/L	8.0 µg/L
Sample 7	4.3 µg/L	Not detected	4.6 µg/L	9.6 µg/L
Sample 8	4.4 µg/L	Not detected	4.2 µg/L	8.4 µg/L
Sample 9	4.2 µg/L	2.7 µg/L	Not detected	7.4 µg/L
Sample 10	4.8 µg/L	Not detected	Not detected	8.5 µg/L
Sample 11	5.8 µg/L	Not detected	Not detected	6.9 µg/L
Sample 12	5.3 µg/L	Not detected	2.2 µg/L	3.9 µg/L
Fully-flushed Sample	Not detected	Not detected	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

3

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/26/2016
 Type of work: Sewer Main Replacement
 Date work performed: 4/27/16

	Samples Collected Before Work Was Performed	Samples Collected 1 Day After Work Was Performed	Samples Collected 2 Weeks After Work Was Performed	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 4/20/16	Date Sample Collected: 4/28/16	Date Sample Collected: 5/9/16	Date Sample Collected: 5/23/16
Sample 1	4.4 µg/L	2.3 µg/L	Not detected	Not detected
Sample 2	5.8 µg/L	3.7 µg/L	3.1 µg/L	Not detected
Sample 3	5.9 µg/L	3.9 µg/L	3.0 µg/L	Not detected
Sample 4	8.6 µg/L	6.4 µg/L	4.4 µg/L	3.4 µg/L
Sample 5	14 µg/L	11 µg/L	8.9 µg/L	7.6 µg/L
Sample 6	15 µg/L	11 µg/L	9.3 µg/L	8.6 µg/L
Sample 7	14 µg/L	11 µg/L	8.8 µg/L	7.2 µg/L
Sample 8	13 µg/L	11 µg/L	8.7 µg/L	6.8 µg/L
Sample 9	13 µg/L	9.6 µg/L	7.7 µg/L	6.5 µg/L
Sample 10	12 µg/L	9.5 µg/L	6.9 µg/L	6.1 µg/L
Sample 11	12 µg/L	9.6 µg/L	8.1 µg/L	6.3 µg/L
Sample 12	12 µg/L	10 µg/L	8.2 µg/L	6.0 µg/L
Fully-flushed Sample	5.1 µg/L	3.9 µg/L	4.8 µg/L	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/26/2016
 Type of work: Sewer Main Replacement
 Date work performed: 4/26/16

	Samples Collected Before Work Was Performed	Samples Collected 1 Day After Work Was Performed	Samples Collected 2 Weeks After Work Was Performed	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 4/16/16	Date Sample Collected: 4/27/16	Date Sample Collected: 5/10/16	Date Sample Collected: 5/23/16
Sample 1	3.0 µg/L	3.7 µg/L	2.6 µg/L	3.0 µg/L
Sample 2	5.6 µg/L	4.6 µg/L	2.8 µg/L	3.6 µg/L
Sample 3	2.8 µg/L	3.4 µg/L	3.8 µg/L	4.9 µg/L
Sample 4	5.2 µg/L	4.2 µg/L	3.8 µg/L	4.6 µg/L
Sample 5	8.7 µg/L	5.0 µg/L	5.3 µg/L	6.3 µg/L
Sample 6	8.7 µg/L	4.3 µg/L	13 µg/L	4.9 µg/L
Sample 7	7.7 µg/L	5.0 µg/L	14 µg/L	5.6 µg/L
Sample 8	10 µg/L	4.4 µg/L	14 µg/L	6.6 µg/L
Sample 9	6.3 µg/L	4.4 µg/L	14 µg/L	5.2 µg/L
Sample 10	4.1 µg/L	5.1 µg/L	13 µg/L	4.6 µg/L
Sample 11	6.5 µg/L	4.7 µg/L	9.2 µg/L	2.5 µg/L
Sample 12	6.0 µg/L	4.3 µg/L	7.0 µg/L	Not detected
Fully-flushed Sample	Not detected	Not detected	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

5

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/26/2016
 Type of work: Sewer Main Replacement
 Date work performed: 4/25/16

	Samples Collected Before Work Was Performed	Samples Collected 1 Day After Work Was Performed	Samples Collected 2 Weeks After Work Was Performed	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 4/9/16	Date Sample Collected: 4/26/16	Date Sample Collected: 5/10/16	Date Sample Collected: 5/24/16
Sample 1	3.6 µg/L	37 µg/L	3.2 µg/L	Not detected
Sample 2	3.7 µg/L	20 µg/L	4.0 µg/L	Not detected
Sample 3	5.4 µg/L	17 µg/L	6.0 µg/L	2.1 µg/L
Sample 4	8.0 µg/L	6.5 µg/L	6.7 µg/L	Not detected
Sample 5	9.0 µg/L	7.1 µg/L	7.2 µg/L	4.9 µg/L
Sample 6	10 µg/L	10 µg/L	8.1 µg/L	6.4 µg/L
Sample 7	5.8 µg/L	7.8 µg/L	8.0 µg/L	6.7 µg/L
Sample 8	5.4 µg/L	34 µg/L	9.3 µg/L	7.1 µg/L
Sample 9	3.7 µg/L	77 µg/L	8.1 µg/L	6.7 µg/L
Sample 10	3.5 µg/L	41 µg/L	9.1 µg/L	7.3 µg/L
Sample 11	3.0 µg/L	9.6 µg/L	18 µg/L	14 µg/L
Sample 12	Not detected	7.5 µg/L	19 µg/L	9.5 µg/L
Fully-flushed Sample	2.5 µg/L	Not detected	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Full Lead Service Line Replaced

Milwaukee Water Works

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy

Date of Report: 5/26/2016

Type of work: City Lead Service Line Replaced; Owner Previously Replaced Lead Service Line

Date work performed: 4/18/2016

	Samples Collected 2 Days After Work Was Performed ¹	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 4/20/16 ¹	Date Sample Collected: 5/24/16 ^{1,2}	Date Sample Collected:
Sample 1	69 µg/L	Not detected	µg/L
Sample 2	Not detected	Not detected	µg/L
Sample 3	Not detected	Not detected	µg/L
Sample 4	Not detected	Not detected	µg/L
Sample 5	2.1 µg/L	Not detected	µg/L
Sample 6	Not detected	Not detected	µg/L
Sample 7	Not detected	Not detected	µg/L
Sample 8	Not detected	Not detected	µg/L
Sample 9	8.1 µg/L	Not detected	µg/L
Sample 10	Not detected	Not detected	µg/L
Sample 11	Not detected	Not detected	µg/L
Sample 12	5.1 µg/L	Not detected	µg/L
Fully-flushed Sample	Not detected	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

- 1) Note to Customer: The sample bottles were returned with incomplete paperwork. For future sample collection, please include the completed paperwork with the sample bottles. Thank you.
- 2) Sample collection date estimated based on date samples were retrieved by laboratory personnel.

Lon Couillard
Water Quality Manager
Milwaukee Water Works
(414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

8

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**
 Date of Report: 3/14/2016
 Type of work: Full Lead Service Line Replacement (Internal Plumbing is Lead)
 Date work performed: 12/2/2015

	Samples Collected Before Work Was Performed	Samples Collected 1 Day After Work Was Performed	Samples Collected 85 Days After Work Was Performed
	Date Sample Collected: 9/6/2015	Date Sample Collected: 12/3/2016	Date Sample Collected: 2/24/16
Sample 1	7.2 µg/L	14 µg/L	6.7µg/L
Sample 2	27 µg/L	46 µg/L	28 µg/L
Sample 3	27 µg/L	23 µg/L	24 µg/L
Sample 4	23 µg/L	11 µg/L	12 µg/L
Sample 5	21 µg/L	10 µg/L	9.2 µg/L
Sample 6	19 µg/L	6.1 µg/L	7.6 µg/L
Sample 7	18 µg/L	4.2 µg/L	4.9 µg/L
Sample 8	17 µg/L	2.2 µg/L	3.7 µg/L
Sample 9	18 µg/L	<2.0 µg/L	3.2 µg/L
Sample 10	18 µg/L	3.1 µg/L	3.2 µg/L
Sample 11	16 µg/L	<2.0 µg/L	2.6 µg/L
Sample 12	15 µg/L	<2.0 µg/L	2.2 µg/L
Fully-flushed Sample	3.0 µg/L	<2.0 µg/L	<2.0 µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**

Date of Report: 4/26/2016

Type of work: City Lead Service Line Replaced; Homeowner Lead Service Line Replaced 4/15/16

Date work performed: 4/15/2016

	Samples Collected 6 Days After Work Was Performed ¹	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 4/21/16 ¹	Date Sample Collected:
Sample 1	69 µg/L	µg/L
Sample 2	14 µg/L	µg/L
Sample 3	5.6 µg/L	µg/L
Sample 4	3.5 µg/L	µg/L
Sample 5	4.5 µg/L	µg/L
Sample 6	3.2 µg/L	µg/L
Sample 7	4.1 µg/L	µg/L
Sample 8	3.4 µg/L	µg/L
Sample 9	3.9 µg/L	µg/L
Sample 10	3.4 µg/L	µg/L
Sample 11	2.7 µg/L	µg/L
Sample 12	Not detected	µg/L
Fully-flushed Sample	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

1) The paperwork indicates the samples were not collected from the kitchen tap. The samples were collected from the water service just inside the building.

Lon Couillard
Water Quality Manager
Milwaukee Water Works
(414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

10

WATER SAMPLE TEST RESULTS FOR LEAD

Address:

Ex. 6 - Personal Privacy

Date of Report:

5/25/2016

Type of work:

Owners Side Lead Service Line Replaced 3/12/16 –
City Side Lead Service Line Replaced 3/24/16

Date work performed:

3/12/2016 and 3/24/16

	Samples Collected 7 Days After Owner's Work Was Performed	Samples Collected 2 Days After MWW Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 3/19/2016	Date Sample Collected: 3/26/16	Date Sample Collected: 4/20/16	Date Sample Collected: 5/20/16
Sample 1	12 µg/L	2.2 µg/L	3.9 µg/L	Not detected
Sample 2	11 µg/L	3.8 µg/L	4.2 µg/L	2.6 µg/L
Sample 3	8.0 µg/L	5.4 µg/L	2.4 µg/L	2.1 µg/L
Sample 4	11 µg/L	5.2 µg/L	3.6 µg/L	2.0 µg/L
Sample 5	16 µg/L	8.2 µg/L	4.8 µg/L	2.9 µg/L
Sample 6	12 µg/L	3.0 µg/L	2.5 µg/L	2.0 µg/L
Sample 7	5.6 µg/L	3.3 µg/L	Not detected	Not detected
Sample 8	7.0 µg/L	2.2 µg/L	Not detected	Not detected
Sample 9	5.7 µg/L	3.5 µg/L	Not detected	Not detected
Sample 10	4.3 µg/L	Not detected	Not detected	Not detected
Sample 11	13 µg/L	2.2 µg/L	Not detected	Not detected
Sample 12	11 µg/L	2.1 µg/L	Not detected	Not detected
Fully-flushed Sample	Not detected	Not detected	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
Water Quality Manager
Milwaukee Water Works
(414) 286-2226
lon.couillard@milwaukee.gov

City Lead Service Line Replaced

Milwaukee Water Works

12

WATER SAMPLE TEST RESULTS FOR LEAD

Address:

Ex. 6 - Personal Privacy

Date of Report:

5/3/2016

Type of work:

City Lead Service Line Replaced

Date work performed:

4/20/2016

	Samples Collected 5 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 4/25/16	Date Sample Collected:
Sample 1	4.1 µg/L	µg/L
Sample 2	4.4 µg/L	µg/L
Sample 3	3.2 µg/L	µg/L
Sample 4	3.2 µg/L	µg/L
Sample 5	4.2 µg/L	µg/L
Sample 6	2.0 µg/L	µg/L
Sample 7	2.6 µg/L	µg/L
Sample 8	Not detected	µg/L
Sample 9	Not detected	µg/L
Sample 10	Not detected	µg/L
Sample 11	Not detected	µg/L
Sample 12	Not detected	µg/L
Fully-flushed Sample	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
Water Quality Manager
Milwaukee Water Works
(414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

13

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/17/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 3/28/2016

	Samples Collected 3 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 3/31/16	Date Sample Collected: 5/14/16	Date Sample Collected:
Sample 1	11 µg/L	Not detected	µg/L
Sample 2	9.4 µg/L	8.0 µg/L	µg/L
Sample 3	14 µg/L	4.5 µg/L	µg/L
Sample 4	22 µg/L	4.3 µg/L	µg/L
Sample 5	16 µg/L	4.1 µg/L	µg/L
Sample 6	4.5 µg/L	4.5 µg/L	µg/L
Sample 7	2.7 µg/L	5.7 µg/L	µg/L
Sample 8	2.9 µg/L	6.9 µg/L	µg/L
Sample 9	3.1 µg/L	2.2 µg/L	µg/L
Sample 10	2.7 µg/L	Not detected	µg/L
Sample 11	3.9 µg/L	Not detected	µg/L
Sample 12	3.0 µg/L	Not detected	µg/L
Fully-flushed Sample	Not detected	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

14

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/17/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 3/28/2016

	Samples Collected 3 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 3/31/16	Date Sample Collected: 5/17/16	Date Sample Collected:
Sample 1	13 µg/L	5.7 µg/L	µg/L
Sample 2	7.0 µg/L	5.5 µg/L	µg/L
Sample 3	13 µg/L	2.1 µg/L	µg/L
Sample 4	35 µg/L	Not detected	µg/L
Sample 5	29 µg/L	Not detected	µg/L
Sample 6	18 µg/L	Not detected	µg/L
Sample 7	6.1 µg/L	Not detected	µg/L
Sample 8	Not detected	Not detected	µg/L
Sample 9	Not detected	Not detected	µg/L
Sample 10	Not detected	Not detected	µg/L
Sample 11	Not detected	Not detected	µg/L
Sample 12	Not detected	Not detected	µg/L
Fully-flushed Sample	Not detected	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

15

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/26/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 5/16/2016

	Samples Collected 5 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 5/21/16	Date Sample Collected:	Date Sample Collected:
Sample 1	4.0 µg/L	µg/L	µg/L
Sample 2	2.3 µg/L	µg/L	µg/L
Sample 3	Not detected	µg/L	µg/L
Sample 4	4.9 µg/L	µg/L	µg/L
Sample 5	Not detected	µg/L	µg/L
Sample 6	3.7 µg/L	µg/L	µg/L
Sample 7	2.3 µg/L	µg/L	µg/L
Sample 8	3.6 µg/L	µg/L	µg/L
Sample 9	2.5 µg/L	µg/L	µg/L
Sample 10	3.4 µg/L	µg/L	µg/L
Sample 11	Not detected	µg/L	µg/L
Sample 12	2.8 µg/L	µg/L	µg/L
Fully-flushed Sample	Not detected	µg/L	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

16

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/5/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 5/2/2016

	Samples Collected 2 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 5/4/16	Date Sample Collected:
Sample 1	Not detected	µg/L
Sample 2	Not detected	µg/L
Sample 3	Not detected	µg/L
Sample 4	Not detected	µg/L
Sample 5	2.3 µg/L	µg/L
Sample 6	2.4 µg/L	µg/L
Sample 7	Not detected	µg/L
Sample 8	Not detected	µg/L
Sample 9	Not detected	µg/L
Sample 10	Not detected	µg/L
Sample 11	Not detected	µg/L
Sample 12	Not detected	µg/L
Fully-flushed Sample	Not detected	µg/L

* This property is a duplex.

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

17

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/12/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 5/6/2016

	Samples Collected 4 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 5/10/16 ¹	Date Sample Collected:	Date Sample Collected:
Sample 1	Not detected	µg/L	µg/L
Sample 2	Not detected	µg/L	µg/L
Sample 3	Not detected	µg/L	µg/L
Sample 4	<i>Not Sampled</i>	µg/L	µg/L
Sample 5	Not detected	µg/L	µg/L
Sample 6	Not detected	µg/L	µg/L
Sample 7	Not detected	µg/L	µg/L
Sample 8	Not detected	µg/L	µg/L
Sample 9	<i>Not Sampled</i>	µg/L	µg/L
Sample 10	Not detected	µg/L	µg/L
Sample 11	Not detected	µg/L	µg/L
Sample 12	<i>Not Sampled</i>	µg/L	µg/L
Fully-flushed Sample	Not detected	µg/L	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

- 1) Note to Customer: Sample bottles 4, 9, and 12 were returned unfilled. For future sample collection, please fill all 13 bottles per the sampling procedure. Thank you.

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

18

WATER SAMPLE TEST RESULTS FOR LEAD

Address:

Ex. 6 - Personal Privacy

Date of Report:

3/14/2016

Type of work:

City Lead Service Line Replacement

Date work performed:

3/9/2016

	Samples Collected 2 Days After Work Was Performed	Samples Collected ____ Days After Work Was Performed
	Date Sample Collected: 3/11/16	Date Sample Collected:
Sample 1	<2.0 µg/L	µg/L
Sample 2	2.8 µg/L	µg/L
Sample 3	2.3 µg/L	µg/L
Sample 4	<2.0 µg/L	µg/L
Sample 5	<2.0 µg/L	µg/L
Sample 6	<2.0 µg/L	µg/L
Sample 7	<2.0 µg/L	µg/L
Sample 8	<2.0 µg/L	µg/L
Sample 9	<2.0 µg/L	µg/L
Sample 10	<2.0 µg/L	µg/L
Sample 11	<2.0 µg/L	µg/L
Sample 12	<2.0 µg/L	µg/L
Fully-flushed Sample	9.1 µg/L	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
Water Quality Manager
Milwaukee Water Works
(414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

19

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**
 Date of Report: 5/24/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 4/12/2016

	Samples Collected 4 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected ____ After Work Was Performed
	Date Sample Collected: 4/16/16	Date Sample Collected: 5/18/16	Date Sample Collected:
Sample 1	5.8 µg/L	Not detected	µg/L
Sample 2	6.0 µg/L	Not detected	µg/L
Sample 3	4.2 µg/L	Not detected	µg/L
Sample 4	6.7 µg/L	Not detected	µg/L
Sample 5	6.5 µg/L	Not detected	µg/L
Sample 6	3.7 µg/L	Not detected	µg/L
Sample 7	3.6 µg/L	Not detected	µg/L
Sample 8	2.3 µg/L	Not detected	µg/L
Sample 9	Not detected	Not detected	µg/L
Sample 10	Not detected	Not detected	µg/L
Sample 11	Not detected	Not detected	µg/L
Sample 12	Not detected	Not detected	µg/L
Fully-flushed Sample	5.7 µg/L	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

20

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**
 Date of Report: 5/24/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 4/12/2016

	Samples Collected 3 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected ____ After Work Was Performed
	Date Sample Collected: 4/15/16	Date Sample Collected: 5/18/16	Date Sample Collected:
Sample 1	8.9 µg/L	4.2 µg/L	µg/L
Sample 2	17 µg/L	8.6 µg/L	µg/L
Sample 3	14 µg/L	8.7 µg/L	µg/L
Sample 4	13 µg/L	7.7 µg/L	µg/L
Sample 5	14 µg/L	7.3 µg/L	µg/L
Sample 6	12 µg/L	6.4 µg/L	µg/L
Sample 7	7.9 µg/L	4.2 µg/L	µg/L
Sample 8	4.7 µg/L	4.1 µg/L	µg/L
Sample 9	5.5 µg/L	2.2 µg/L	µg/L
Sample 10	6.5 µg/L	3.4 µg/L	µg/L
Sample 11	30 µg/L	Not detected	µg/L
Sample 12	11 µg/L	Not detected	µg/L
Fully-flushed Sample	3.4 µg/L	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

21

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**
 Date of Report: 5/24/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 4/12/2016

	Samples Collected ____ Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected ____ After Work Was Performed
	Date Sample Collected:	Date Sample Collected: 5/18/16	Date Sample Collected:
Sample 1	Not sampled	Not detected	µg/L
Sample 2	Not sampled	Not detected	µg/L
Sample 3	Not sampled	3.7 µg/L	µg/L
Sample 4	Not sampled	2.3 µg/L	µg/L
Sample 5	Not sampled	Not detected	µg/L
Sample 6	Not sampled	Not detected	µg/L
Sample 7	Not sampled	Not detected	µg/L
Sample 8	Not sampled	Not detected	µg/L
Sample 9	Not sampled	Not detected	µg/L
Sample 10	Not sampled	Not detected	µg/L
Sample 11	Not sampled	Not detected	µg/L
Sample 12	Not sampled	Not detected	µg/L
Fully-flushed Sample	Not sampled	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/16/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 4/6/2016

	Samples Collected 2 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 4/8/16	Date Sample Collected: 5/12/16
Sample 1	Not detected	Not detected
Sample 2	3.5 µg/L	Not detected
Sample 3	2.7 µg/L	3.1 µg/L
Sample 4	2.3 µg/L	Not detected
Sample 5	3.5 µg/L	Not detected
Sample 6	2.7 µg/L	3.1 µg/L
Sample 7	3.7 µg/L	Not detected
Sample 8	3.7 µg/L	Not detected
Sample 9	2.6 µg/L	3.0 µg/L
Sample 10	3.2 µg/L	Not detected
Sample 11	4.8 µg/L	2.0 µg/L
Sample 12	5.0 µg/L	Not detected
Fully-flushed Sample	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

23

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**
 Date of Report: 5/25/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 2/29/2016

	Samples Collected 6 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 3/6/16	Date Sample Collected: 4/10/16	Date Sample Collected: 5/23/16
Sample 1	Not detected	Not detected	Not detected
Sample 2	Not detected	Not detected	Not detected
Sample 3	2.4 µg/L	Not detected	Not detected
Sample 4	Not detected	Not detected	Not detected
Sample 5	2.4 µg/L	Not detected	Not detected
Sample 6	Not detected	Not detected	Not detected
Sample 7	Not detected	Not detected	Not detected
Sample 8	Not detected	Not detected	Not detected
Sample 9	Not detected	Not detected	Not detected
Sample 10	Not detected	Not detected	Not detected
Sample 11	Not detected	Not detected	Not detected
Sample 12	3.9 µg/L	Not detected	Not detected
Fully-flushed Sample	2.8 µg/L	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

24

WATER SAMPLE TEST RESULTS FOR LEAD

Address:

Ex. 6 - Personal Privacy

Date of Report:

4/4/2016

Type of work:

City Lead Service Line Replaced

Date work performed:

2/29/2016

	Samples Collected 7 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 3/7/16	Date Sample Collected: 3/31/16
Sample 1	4.5 µg/L	<2.0µg/L
Sample 2	5.2 µg/L	<2.0 µg/L
Sample 3	3.4 µg/L	3.0 µg/L
Sample 4	2.6 µg/L	5.1 µg/L
Sample 5	2.7 µg/L	<2.0 µg/L
Sample 6	2.5 µg/L	<2.0 µg/L
Sample 7	<2.0 µg/L	<2.0 µg/L
Sample 8	<2.0 µg/L	<2.0 µg/L
Sample 9	<2.0 µg/L	<2.0 µg/L
Sample 10	<2.0 µg/L	<2.0 µg/L
Sample 11	<2.0 µg/L	<2.0 µg/L
Sample 12	<2.0 µg/L	<2.0 µg/L
Fully-flushed Sample	<2.0 µg/L	<2.0 µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
Water Quality Manager
Milwaukee Water Works
(414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

25

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**
 Date of Report: 5/17/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 2/29/2016

	Samples Collected 3 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 3/2/16	Date Sample Collected: 3/31/16	Date Sample Collected: 5/12/16 ¹
Sample 1	Not detected	2.8 µg/L	Not detected
Sample 2	Not detected	3.2 µg/L	Not detected
Sample 3	Not detected	3.1 µg/L	Not detected
Sample 4	2.4 µg/L	3.6 µg/L	Not detected
Sample 5	Not detected	2.9 µg/L	Not detected
Sample 6	Not detected	Not detected	Not detected
Sample 7	Not detected	Not detected	Not detected
Sample 8	Not detected	Not detected	Not detected
Sample 9	Not detected	Not detected	Not detected
Sample 10	Not detected	Not detected	Not detected
Sample 11	2.5 µg/L	Not detected	Not detected
Sample 12	Not detected	Not detected	Not detected
Fully-flushed Sample	Not detected	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

- 1) Note to Customer: The sample bottles were returned without the completed paperwork. For future sample collection, please include the completed paperwork with the sample bottles. Thank you.

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

26

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**
 Date of Report: 5/17/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 3/30/2016

	Samples Collected 8 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 4/7/16	Date Sample Collected: 5/13/16	Date Sample Collected:
Sample 1	14 µg/L	Not detected	µg/L
Sample 2	Not detected	Not detected	µg/L
Sample 3	2.8 µg/L	Not detected	µg/L
Sample 4	Not detected	Not detected	µg/L
Sample 5	Not detected	Not detected	µg/L
Sample 6	Not detected	Not detected	µg/L
Sample 7	Not detected	Not detected	µg/L
Sample 8	Not detected	Not detected	µg/L
Sample 9	Not detected	Not detected	µg/L
Sample 10	Not detected	Not detected	µg/L
Sample 11	Not detected	Not detected	µg/L
Sample 12	Not detected	Not detected	µg/L
Fully-flushed Sample	Not detected	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

27

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/9/2016
 Type of work: City Lead Service Line Replacement
 Date work performed: 2/19/2016

	Samples Collected 3 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 2/22/16	Date Sample Collected: 3/22/16	Date Sample Collected: 5/05/16
Sample 1	2.2 µg/L	Not detected	Not detected
Sample 2	Not detected	Not detected	Not detected
Sample 3	Not detected L	Not detected	Not detected
Sample 4	2.6 µg/L	Not detected	Not detected
Sample 5	2.1 µg/L	Not detected	Not detected
Sample 6	Not detected	Not detected	Not detected
Sample 7	Not detected	Not detected	Not detected
Sample 8	2.3 µg/L	Not detected	Not detected
Sample 9	2.0 µg/L	Not detected	Not detected
Sample 10	2.4 µg/L	Not detected	Not detected
Sample 11	2.5 µg/L	Not detected	Not detected
Sample 12	2.0 µg/L	Not detected	Not detected
Fully-flushed Sample	Not detected	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

28

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**
 Date of Report: 5/17/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 3/1/2016

	Samples Collected Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected:	Date Sample Collected: 4/4/16	Date Sample Collected: 5/13/16
Sample 1	µg/L	3.0 µg/L	2.2 µg/L
Sample 2	µg/L	Not detected	Not detected
Sample 3	µg/L	2.2 µg/L	2.4 µg/L
Sample 4	µg/L	Not detected	Not detected
Sample 5	µg/L	7.2 µg/L	4.9 µg/L
Sample 6	µg/L	17 µg/L	12 µg/L
Sample 7	µg/L	12 µg/L	12 µg/L
Sample 8	µg/L	15 µg/L	13 µg/L
Sample 9	µg/L	7.3 µg/L	6.7 µg/L
Sample 10	µg/L	Not detected	2.9 µg/L
Sample 11	µg/L	Not detected	Not detected
Sample 12	µg/L	Not detected	Not detected
Fully-flushed Sample	µg/L	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

**Note: 2514 South Brisbane Avenue is the second side of a duplex. Please refer to 2516 South Brisbane Avenue for additional results.*

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

29

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**
 Date of Report: 5/17/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 3/1/2016

	Samples Collected 1 Day After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 3/2/16	Date Sample Collected: 4/4/16	Date Sample Collected: 5/13/16
Sample 1	6.4 µg/L	3.9 µg/L	Not detected
Sample 2	5.6 µg/L	6.5 µg/L	Not detected
Sample 3	13 µg/L	4.3 µg/L	Not detected
Sample 4	10 µg/L	6.1 µg/L	2.1 µg/L
Sample 5	41 µg/L	5.1 µg/L	Not detected
Sample 6	43 µg/L	4.1 µg/L	Not detected
Sample 7	20 µg/L	4.6 µg/L	Not detected
Sample 8	77 µg/L	3.5 µg/L	Not detected
Sample 9	37 µg/L	5.8 µg/L	Not detected
Sample 10	12 µg/L	4.3 µg/L	Not detected
Sample 11	7.4 µg/L	4.8 µg/L	Not detected
Sample 12	5.5 µg/L	Not detected	Not detected
Fully-flushed Sample	Not detected	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

**Note: 2516 South Brisbane Avenue is the second side of a duplex. Please refer to 2514 South Brisbane Avenue for additional results.*

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

30

WATER SAMPLE TEST RESULTS FOR LEAD

Address:

Ex. 6 - Personal Privacy

Date of Report:

5/3/2016

Type of work:

City Lead Service Line Replaced

Date work performed:

3/15/2016

	Samples Collected 3 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 3/18/16	Date Sample Collected: 4/26/16
Sample 1	62 µg/L	4.1 µg/L
Sample 2	4.6 µg/L	4.9 µg/L
Sample 3	9.8 µg/L	2.5 µg/L
Sample 4	9.7 µg/L	2.5 µg/L
Sample 5	11 µg/L	4.6 µg/L
Sample 6	20 µg/L	11 µg/L
Sample 7	26 µg/L	18 µg/L
Sample 8	33 µg/L	18 µg/L
Sample 9	28 µg/L	18 µg/L
Sample 10	35 µg/L	19 µg/L
Sample 11	72 µg/L	19 µg/L
Sample 12	64 µg/L	17 µg/L
Fully-flushed Sample	Not detected	<2.0 µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
Water Quality Manager
Milwaukee Water Works
(414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

31

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/19/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 4/7/2016

	Samples Collected 2 Days After Work Was Performed	Samples Collected 13 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed ¹
	Sample Collected from BATHROOM TAP on 4/09/2016	Sample Collected from KITCHEN TAP on 4/20/16	Date Sample Collected: 5/18/16 ¹
Sample 1	820 µg/L	7.5 µg/L	Not detected
Sample 2	8.9 µg/L	3.3 µg/L	Not detected
Sample 3	410 µg/L	Not detected	Not detected
Sample 4	14 µg/L	Not detected	Not detected
Sample 5	8.7 µg/L	Not detected	Not detected
Sample 6	7.2 µg/L	Not detected	Not detected
Sample 7	11 µg/L	Not detected	Not detected
Sample 8	Not detected	Not detected	Not detected
Sample 9	Not detected	Not detected	Not detected
Sample 10	5.1 µg/L	Not detected	Not detected
Sample 11	3.7 µg/L	Not detected	Not detected
Sample 12	2.1 µg/L	Not detected	Not detected
Fully-flushed Sample	Not detected	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

1) Note to Customer: Please return completed paperwork with future samples. Thank you.

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

32

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 4/6/2016
 Type of work: City Lead Service Line Replacement
 Date work performed: 3/1/2016

	Samples Collected 1 Day After Work Was Performed	Samples Collected 1 Week After Work Was Performed ¹	Samples Collected 1 Month After Work Was Performed ²
	Date Sample Collected: 3/2/16	Date Sample Collected: 3/8/2016	Date Sample Collected: 4/3/16
Sample 1	420 µg/L	<2.0 µg/L	<2.0 µg/L
Sample 2	6.0 µg/L	<2.0 µg/L	<2.0 µg/L
Sample 3	4.9 µg/L	µg/L	<2.0 µg/L
Sample 4	<2.0 µg/L	µg/L	<2.0 µg/L
Sample 5	< 2.0 µg/L	µg/L	<2.0 µg/L
Sample 6	<2.0 µg/L	µg/L	<2.0 µg/L
Sample 7	<2.0 µg/L	µg/L	<2.0 µg/L
Sample 8	2.2 µg/L	µg/L	<2.0 µg/L
Sample 9	<2.0 µg/L	µg/L	<2.0 µg/L
Sample 10	<2.0 µg/L	µg/L	<2.0 µg/L
Sample 11	<2.0 µg/L	µg/L	<2.0 µg/L
Sample 12	<2.0 µg/L	µg/L	<2.0 µg/L
Fully-flushed Sample	10 µg/L	<2.0 µg/L	<2.0 µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

1) Resample of liters 1 and 2, and Fully-flushed on 3/8/16.

2) Completed form indicates water usage within 6 hour period prior to sample collection for final set.

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

33

WATER SAMPLE TEST RESULTS FOR LEAD

Address:

Ex. 6 - Personal Privacy

Date of Report:

4/8/2016

Type of work:

City Lead Service Line Replaced

Date work performed:

3/1/2016

	Samples Collected 2 Days After Work Was Performed ¹	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 3/3/16	Date Sample Collected: 4/6/16
Sample 1	<2.0 µg/L	<2.0 µg/L
Sample 2	<2.0 µg/L	<2.0 µg/L
Sample 3	2.9 µg/L	<2.0 µg/L
Sample 4	2.3 µg/L	<2.0 µg/L
Sample 5	<2.0 µg/L	4.9 µg/L
Sample 6	<2.0 µg/L	7.6 µg/L
Sample 7	<2.0 µg/L	6.4 µg/L
Sample 8	<2.0 µg/L	6.8 µg/L
Sample 9	<2.0 µg/L	6.0 µg/L
Sample 10	<2.0 µg/L	3.9 µg/L
Sample 11	<2.0 µg/L	<2.0 µg/L
Sample 12	<2.0 µg/L	<2.0 µg/L
Fully-flushed Sample	<2.0 µg/L	<2.0 µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

1) Completed form indicates water usage within 6 hour period prior to sample collection for first set.

Lon Couillard
Water Quality Manager
Milwaukee Water Works
(414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

34

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/19/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 5/16/2016

	Samples Collected 1 Day After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 5/17/16	Date Sample Collected:	Date Sample Collected:
Sample 1	6.6 µg/L	µg/L	µg/L
Sample 2	Not detected	µg/L	µg/L
Sample 3	Not detected	µg/L	µg/L
Sample 4	Not detected	µg/L	µg/L
Sample 5	Not detected	µg/L	µg/L
Sample 6	Not detected	µg/L	µg/L
Sample 7	Not detected	µg/L	µg/L
Sample 8	Not detected	µg/L	µg/L
Sample 9	Not detected	µg/L	µg/L
Sample 10	Not detected	µg/L	µg/L
Sample 11	Not detected	µg/L	µg/L
Sample 12	Not detected	µg/L	µg/L
Fully-flushed Sample	Not detected	µg/L	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

35

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/10/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 4/2/2016

	Samples Collected 4 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected ____ Months After Work Was Performed
	Date Sample Collected: 4/6/16	Date Sample Collected: 5/06/16	Date Sample Collected:
Sample 1	7.8 µg/L	Not detected	µg/L
Sample 2	4.1 µg/L	Not detected	µg/L
Sample 3	5.5 µg/L	Not detected	µg/L
Sample 4	3.8 µg/L	Not detected	µg/L
Sample 5	2.9 µg/L	Not detected	µg/L
Sample 6	Not detected	Not detected	µg/L
Sample 7	Not detected	Not detected	µg/L
Sample 8	Not detected	Not detected	µg/L
Sample 9	Not detected	Not detected	µg/L
Sample 10	Not detected	Not detected	µg/L
Sample 11	2.1 µg/L	Not detected	µg/L
Sample 12	Not detected	Not detected	µg/L
Fully-flushed Sample	2.5 µg/L	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/3/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 4/26/2016

	Samples Collected 2 Days After Work Was Performed ¹	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 4/28/16 ¹	Date Sample Collected:
Sample 1	33 µg/L	µg/L
Sample 2	22 µg/L	µg/L
Sample 3	19 µg/L	µg/L
Sample 4	41 µg/L	µg/L
Sample 5	11 µg/L	µg/L
Sample 6	17 µg/L	µg/L
Sample 7	15 µg/L	µg/L
Sample 8	10 µg/L	µg/L
Sample 9	9.0 µg/L	µg/L
Sample 10	8.6 µg/L	µg/L
Sample 11	9.2 µg/L	µg/L
Sample 12	7.4 µg/L	µg/L
Fully-flushed Sample	14 µg/L	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

- 1) **Note to Customer:** Please call to let us know the exact date that the sample was collected, from which tap, and whether the water was undisturbed in the pipes for six hours prior to sample collection. Alternately, please return the attached form in the mail or with the next set of samples when they are collected. Thank you.

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

37

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 6/2/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 4/20/2016

	Samples Collected 1 Day After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 4/21/16	Date Sample Collected: 5/26/16	Date Sample Collected:
Sample 1	8.8 µg/L	4.0 µg/L	µg/L
Sample 2	9.9 µg/L	2.9 µg/L	µg/L
Sample 3	11 µg/L	2.8 µg/L	µg/L
Sample 4	28 µg/L	2.2 µg/L	µg/L
Sample 5	37 µg/L	2.4 µg/L	µg/L
Sample 6	36 µg/L	2.8 µg/L	µg/L
Sample 7	21 µg/L	2.1 µg/L	µg/L
Sample 8	16 µg/L	2.4 µg/L	µg/L
Sample 9	14 µg/L	2.3 µg/L	µg/L
Sample 10	12 µg/L	2.1 µg/L	µg/L
Sample 11	36 µg/L	2.4 µg/L	µg/L
Sample 12	124 µg/L	Not detected	µg/L
Fully-flushed Sample	2.3 µg/L	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

38

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**
 Date of Report: 6/1/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 4/15/2016

	Samples Collected 4 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 4/19/16	Date Sample Collected: 5/24/16	Date Sample Collected:
Sample 1	7.6 µg/L	Not detected	µg/L
Sample 2	10 µg/L	Not detected	µg/L
Sample 3	11 µg/L	Not detected	µg/L
Sample 4	19 µg/L	3.1 µg/L	µg/L
Sample 5	20 µg/L	2.4 µg/L	µg/L
Sample 6	20 µg/L	2.1 µg/L	µg/L
Sample 7	20 µg/L	Not detected	µg/L
Sample 8	53 µg/L	2.3 µg/L	µg/L
Sample 9	190 µg/L	2.1 µg/L	µg/L
Sample 10	120 µg/L	Not detected	µg/L
Sample 11	37 µg/L	2.5 µg/L	µg/L
Sample 12	13 µg/L	Not detected	µg/L
Fully-flushed Sample	Not detected	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

39

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/25/2016
 Type of work: City Lead Service Line Replacement
 Date work performed: 3/14/2016

	Samples Collected 2 Days After Work Was Performed	Samples Collected 1 Week After Work Was Performed ¹	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 3/16/2016	Date Sample Collected: 3/21/2016	Date Sample Collected: 4/20/16	Date Sample Collected: 5/20/16
Sample 1	370 µg/L	2.7 µg/L	2.0 µg/L	Not detected
Sample 2	8.5 µg/L	2.6 µg/L	2.5 µg/L	Not detected
Sample 3	8.8 µg/L	µg/L	4.3 µg/L	Not detected
Sample 4	8.8 µg/L	µg/L	3.3 µg/L	Not detected
Sample 5	5.8 µg/L	µg/L	Not detected	Not detected
Sample 6	7.5 µg/L	µg/L	2.4 µg/L	2.6 µg/L
Sample 7	6.7 µg/L	µg/L	Not detected	6.2 µg/L
Sample 8	7.8 µg/L	µg/L	Not detected	5.9 µg/L
Sample 9	5.9 µg/L	µg/L	Not detected	4.5 µg/L
Sample 10	7.1 µg/L	µg/L	Not detected	5.1 µg/L
Sample 11	6.5 µg/L	µg/L	Not detected	6.9 µg/L
Sample 12	10 µg/L	µg/L	Not detected	8.0 µg/L
Fully-flushed Sample	5.0 µg/L	Not detected	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

1) Resample of liters 1 and 2, and fully-flushed on 3/21/16.

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

40

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 6/1/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 5/23/2016

	Samples Collected 2 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 5/25/16	Date Sample Collected:	Date Sample Collected:
Sample 1	8.3 µg/L	µg/L	µg/L
Sample 2	11 µg/L	µg/L	µg/L
Sample 3	13 µg/L	µg/L	µg/L
Sample 4	13 µg/L	µg/L	µg/L
Sample 5	8.2 µg/L	µg/L	µg/L
Sample 6	3.7 µg/L	µg/L	µg/L
Sample 7	3.7 µg/L	µg/L	µg/L
Sample 8	Not detected	µg/L	µg/L
Sample 9	Not detected	µg/L	µg/L
Sample 10	3.5 µg/L	µg/L	µg/L
Sample 11	Not detected	µg/L	µg/L
Sample 12	Not detected	µg/L	µg/L
Fully-flushed Sample	Not detected	µg/L	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

41

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**
 Date of Report: 6/1/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 3/21/2016

	Samples Collected 5 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 3/26/16	Date Sample Collected: 4/26/16	Date Sample Collected: 5/27/16
Sample 1	2.8 µg/L	Not detected	Not detected
Sample 2	Not detected	Not detected	Not detected
Sample 3	Not detected	Not detected	Not detected
Sample 4	Not detected	Not detected	Not detected
Sample 5	Not detected	Not detected	Not detected
Sample 6	Not detected	Not detected	Not detected
Sample 7	2.2 µg/L	Not detected	Not detected
Sample 8	Not detected	Not detected	Not detected
Sample 9	2.4 µg/L	Not detected	Not detected
Sample 10	Not detected	2.3 µg/L	Not detected
Sample 11	2.3 µg/L	Not detected	Not detected
Sample 12	Not detected	Not detected	Not detected
Fully-flushed Sample	Not detected	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

42

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 4/18/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 4/12/2016

	Samples Collected 2 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 4/14/16	Date Sample Collected:
Sample 1	65 µg/L	µg/L
Sample 2	17 µg/L	µg/L
Sample 3	43 µg/L	µg/L
Sample 4	60 µg/L	µg/L
Sample 5	41 µg/L	µg/L
Sample 6	21 µg/L	µg/L
Sample 7	16 µg/L	µg/L
Sample 8	14 µg/L	µg/L
Sample 9	13 µg/L	µg/L
Sample 10	12 µg/L	µg/L
Sample 11	9.3 µg/L	µg/L
Sample 12	8.8 µg/L	µg/L
Fully-flushed Sample	8.9 µg/L	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

43

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/27/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 5/23/2016

	Samples Collected 2 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 5/25/16	Date Sample Collected:	Date Sample Collected:
Sample 1	2.1 µg/L	µg/L	µg/L
Sample 2	2.9 µg/L	µg/L	µg/L
Sample 3	Not detected	µg/L	µg/L
Sample 4	2.4 µg/L	µg/L	µg/L
Sample 5	2.8 µg/L	µg/L	µg/L
Sample 6	Not detected	µg/L	µg/L
Sample 7	16 µg/L	µg/L	µg/L
Sample 8	19 µg/L	µg/L	µg/L
Sample 9	3.5 µg/L	µg/L	µg/L
Sample 10	Not detected	µg/L	µg/L
Sample 11	Not detected	µg/L	µg/L
Sample 12	Not detected	µg/L	µg/L
Fully-flushed Sample	Not detected	µg/L	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

44

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 3/30/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 2/25/2016

	Samples Collected 2 Days After Work Was Performed ¹	Samples Collected 1 Month After Work Was Performed ¹
	Date Sample Collected: 2/27/16	Date Sample Collected: 3/29/16
Sample 1	<2.0 µg/L	<2.0 µg/L
Sample 2	<2.0 µg/L	<2.0 µg/L
Sample 3	<2.0 µg/L	<2.0 µg/L
Sample 4	<2.0 µg/L	<2.0 µg/L
Sample 5	<2.0 µg/L	<2.0 µg/L
Sample 6	<2.0 µg/L	<2.0 µg/L
Sample 7	<2.0 µg/L	<2.0 µg/L
Sample 8	<2.0 µg/L	<2.0 µg/L
Sample 9	<2.0 µg/L	<2.0 µg/L
Sample 10	<2.0 µg/L	<2.0 µg/L
Sample 11	<2.0 µg/L	<2.0 µg/L
Sample 12	<2.0 µg/L	<2.0 µg/L
Fully-flushed Sample	<2.0 µg/L	<2.0 µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

1) NOTE: Completed forms indicate water usage within 6 hour period prior to sample collection for each sample set.

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

45

WATER SAMPLE TEST RESULTS FOR LEAD

Address:

Ex. 6 - Personal Privacy

Date of Report:

5/4/2016

Type of work:

City Lead Service Line Replaced

Date work performed:

2/19/2016

	Samples Collected 3 Days After Work Was Performed	Samples Collected 9 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 2/22/2016	Date Sample Collected: 2/28/16	Date Sample Collected: 3/23/16	Date Sample Collected: 4/28/16
Sample 1	65 µg/L	43µg/L	5.0 µg/L	4.1 µg/L
Sample 2	31 µg/L	17 µg/L	4.9 µg/L	4.8 µg/L
Sample 3	6.0 µg/L	12 µg/L	7.8 µg/L	4.0 µg/L
Sample 4	5.8 µg/L	13 µg/L	4.7 µg/L	4.3 µg/L
Sample 5	7.1 µg/L	19 µg/L	10 µg/L	7.5 µg/L
Sample 6	12 µg/L	20 µg/L	13 µg/L	9.7 µg/L
Sample 7	10 µg/L	53 µg/L	11 µg/L	8.7 µg/L
Sample 8	10 µg/L	36 µg/L	12 µg/L	8.0 µg/L
Sample 9	7.3 µg/L	18 µg/L	12 µg/L	8.6 µg/L
Sample 10	7.7 µg/L	19 µg/L	13 µg/L	9.8 µg/L
Sample 11	12 µg/L	21 µg/L	14 µg/L	8.0 µg/L
Sample 12	16 µg/L	32 µg/L	11 µg/L	7.3 µg/L
Fully-flushed Sample	2.6 µg/L	Not detected	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
Water Quality Manager
Milwaukee Water Works
(414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

46

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**
 Date of Report: 6/2/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 4/11/2016

	Samples Collected 2 Days After Work Was Performed ¹	Samples Collected 1 Week After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 4/13/16 ¹	Date Sample Collected: 4/18/16	Date Sample Collected: 5/26/16	Date Sample Collected:
Sample 1	14 µg/L	7.5 µg/L	6.8 µg/L	µg/L
Sample 2	5.3 µg/L	5.8 µg/L	5.8 µg/L	µg/L
Sample 3	3.7 µg/L	3.7 µg/L	5.2 µg/L	µg/L
Sample 4	2.9 µg/L	4.2 µg/L	4.1 µg/L	µg/L
Sample 5	4.3 µg/L	4.7 µg/L	3.3 µg/L	µg/L
Sample 6	5.7 µg/L	6.4 µg/L	3.9 µg/L	µg/L
Sample 7	6.7 µg/L	8.2 µg/L	3.9 µg/L	µg/L
Sample 8	6.9 µg/L	8.5 µg/L	3.1 µg/L	µg/L
Sample 9	7.0 µg/L	7.9 µg/L	2.9 µg/L	µg/L
Sample 10	11 µg/L	8.5 µg/L	2.8 µg/L	µg/L
Sample 11	44 µg/L	14 µg/L	2.2 µg/L	µg/L
Sample 12	73 µg/L	20 µg/L	Not detected	µg/L
Fully-flushed Sample	52 µg/L	Not detected	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

- 1) **NOTE:** No paperwork was returned with the sample bottles on the pick-up date of 4/13/16. The collection date and process are not known. The collection date is estimated to be 4/13/16.

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

47

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/3/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 4/21/2016

	Samples Collected 4 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 4/25/16	Date Sample Collected:
Sample 1	Not detected	µg/L
Sample 2	Not detected	µg/L
Sample 3	Not detected	µg/L
Sample 4	Not detected	µg/L
Sample 5	Not detected	µg/L
Sample 6	17 µg/L	µg/L
Sample 7	Not detected	µg/L
Sample 8	Not detected	µg/L
Sample 9	Not detected	µg/L
Sample 10	Not detected	µg/L
Sample 11	Not detected	µg/L
Sample 12	6.8 µg/L	µg/L
Fully-flushed Sample	6.3 µg/L	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

48

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/10/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 2/23/2016

	Samples Collected 2 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 2/25/16	Date Sample Collected: 3/23/16	Date Sample Collected: 5/07/16
Sample 1	6.6 µg/L	2.2 µg/L	3.2 µg/L
Sample 2	4.6 µg/L	Not detected	3.0 µg/L
Sample 3	4.8 µg/L	Not detected	2.2 µg/L
Sample 4	4.2 µg/L	Not detected	Not detected
Sample 5	3.9 µg/L	Not detected	3.0 µg/L
Sample 6	4.8 µg/L	Not detected	Not detected
Sample 7	4.7 µg/L	Not detected	Not detected
Sample 8	5.2 µg/L	Not detected	2.1 µg/L
Sample 9	Not detected	2.1 µg/L	Not detected
Sample 10	2.7 µg/L	Not detected	Not detected
Sample 11	4.0 µg/L	Not detected	Not detected
Sample 12	6.0 µg/L	Not detected	Not detected
Fully-flushed Sample	2.2 µg/L	Not detected	2.9 µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/9/2016
 Type of work: City Lead Service Line Replaced
 Date work performed: 4/25/2016

	Samples Collected 10 Days After Work Was Performed	Samples Collected ____ Days After Work Was Performed
	Date Sample Collected: 5/05/16 ¹	Date Sample Collected:
Sample 1	Not detected	µg/L
Sample 2	Not detected	µg/L
Sample 3	Not detected	µg/L
Sample 4	Not detected	µg/L
Sample 5	Not detected	µg/L
Sample 6	Not detected	µg/L
Sample 7	Not detected	µg/L
Sample 8	Not detected	µg/L
Sample 9	Not detected	µg/L
Sample 10	Not detected	µg/L
Sample 11	Not detected	µg/L
Sample 12	Not detected	µg/L
Fully-flushed Sample	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

- 1) Note to customer: Please call to let us know the exact date that the sample was collected, from which tap, and whether the water was undisturbed in the pipes for six hours prior to sample collection. Alternately, please return the attached form in the mail or with the next set of samples when they are collected. Thank you.

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Meter Valve

Milwaukee Water Works

51

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/12/2016
 Type of work: Meter Valve
 Date work performed: 2/22/2016

	Samples Collected 2 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 2/24/16	Date Sample Collected: 3/23/16	Date Sample Collected: 5/10/16
Sample 1	40 µg/L	Not detected	Not detected
Sample 2	12 µg/L	Not detected	Not detected
Sample 3	6.2 µg/L	3.2 µg/L	Not detected
Sample 4	4.4 µg/L	Not detected	Not detected
Sample 5	4.0 µg/L	Not detected	8.7 µg/L
Sample 6	13 µg/L	Not detected	Not detected
Sample 7	4.0 µg/L	Not detected	Not detected
Sample 8	3.8 µg/L	Not detected	Not detected
Sample 9	4.0 µg/L	Not detected	Not detected
Sample 10	3.3 µg/L	Not detected	Not detected
Sample 11	2.1 µg/L	Not detected	Not detected
Sample 12	2.5 µg/L	Not detected	Not detected
Fully-flushed Sample	Not detected	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

52

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**
 Date of Report: 6/1/2016
 Type of work: Meter Valve Inlet
 Date work performed: 4/19/2016

	Samples Collected 3 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 4/22/16	Date Sample Collected: 5/25/16	Date Sample Collected:
Sample 1	7.5 µg/L	4.8 µg/L	µg/L
Sample 2	7.1 µg/L	6.0 µg/L	µg/L
Sample 3	Not detected	2.6 µg/L	µg/L
Sample 4	Not detected	2.8 µg/L	µg/L
Sample 5	Not detected	2.7 µg/L	µg/L
Sample 6	Not detected	Not detected	µg/L
Sample 7	Not detected	Not detected	µg/L
Sample 8	Not detected	Not detected	µg/L
Sample 9	Not detected	Not detected	µg/L
Sample 10	Not detected	Not detected	µg/L
Sample 11	Not detected	Not detected	µg/L
Sample 12	Not detected	Not detected	µg/L
Fully-flushed Sample	Not detected	2.4 µg/L	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

53

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/10/2016
 Type of work: Meter Valve
 Date work performed: 2/26/2016

	Samples Collected 4 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 3/1/16	Date Sample Collected: 3/29/16	Date Sample Collected: 5/09/16
Sample 1	6.4 µg/L	Not detected	2.2 µg/L
Sample 2	27 µg/L	Not detected	Not detected
Sample 3	11 µg/L	Not detected	Not detected
Sample 4	51 µg/L	2.0 µg/L	2.0 µg/L
Sample 5	84 µg/L	2.1 µg/L	Not detected
Sample 6	20 µg/L	2.1 µg/L	Not detected
Sample 7	72 µg/L	Not detected	Not detected
Sample 8	10 µg/L	2.2 µg/L	Not detected
Sample 9	130 µg/L	2.1 µg/L	2.0 µg/L
Sample 10	5.1 µg/L	Not detected	Not detected
Sample 11	Not detected	3.2 µg/L	Not detected
Sample 12	4.7 µg/L	2.7 µg/L	2.7 µg/L
Fully-flushed Sample	4.2 µg/L	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

54

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**

Date of Report: 4/26/2016

Type of work: Meter Valve

Date work performed: 3/14/2016

	Samples Collected 2 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed
	Date Sample Collected: 3/16/16	Date Sample Collected: 4/21/16
Sample 1	3.0 µg/L	Not detected
Sample 2	Not detected	Not detected
Sample 3	Not detected	Not detected
Sample 4	Not detected	Not detected
Sample 5	Not detected	3.6 µg/L
Sample 6	Not detected	2.2 µg/L
Sample 7	Not detected	Not detected
Sample 8	Not detected	2.1 µg/L
Sample 9	Not detected	Not detected
Sample 10	Not detected	2.0 µg/L
Sample 11	Not detected	Not detected
Sample 12	2.4 µg/L	Not detected
Fully-flushed Sample	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
Water Quality Manager
Milwaukee Water Works
(414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

55

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 5/10/2016
 Type of work: Meter Valve
 Date work performed: 2/16/2016

	Samples Collected 8 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 2/24/16	Date Sample Collected: 3/23/16	Date Sample Collected: 5/06/16
Sample 1	2.0 µg/L	3.6 µg/L	3.2 µg/L
Sample 2	2.2 µg/L	Not detected	2.6 µg/L
Sample 3	2.0 µg/L	4.0 µg/L	2.8 µg/L
Sample 4	22 µg/L	Not detected	3.0 µg/L
Sample 5	20 µg/L	Not detected	2.6 µg/L
Sample 6	10 µg/L	6.4 µg/L	5.7 µg/L
Sample 7	7.8 µg/L	4.0 µg/L	6.0 µg/L
Sample 8	11 µg/L	7.7 µg/L	6.3 µg/L
Sample 9	9.3 µg/L	Not detected	6.1 µg/L
Sample 10	7.7 µg/L	6.6 µg/L	5.6 µg/L
Sample 11	6.7 µg/L	Not detected	4.9 µg/L
Sample 12	5.1 µg/L	6.5 µg/L	5.1 µg/L
Fully-flushed Sample	Not detected	Not detected	Not detected

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov

Owner's Leak Repaired

Milwaukee Water Works

57

WATER SAMPLE TEST RESULTS FOR LEAD

Address: **Ex. 6 - Personal Privacy**

Date of Report: 3/24/2016

Type of work: Owner's Leak – Repaired Leak Only, Not Replaced

Date work performed: 3/16/2016

	Samples Collected 5 Days After Work Was Performed	Samples Collected ____ Days After Work Was Performed
	Date Sample Collected: 3/21/16	Date Sample Collected:
Sample 1	20 µg/L	µg/L
Sample 2	31 µg/L	µg/L
Sample 3	27 µg/L	µg/L
Sample 4	27 µg/L	µg/L
Sample 5	23 µg/L	µg/L
Sample 6	12 µg/L	µg/L
Sample 7	11 µg/L	µg/L
Sample 8	66 µg/L	µg/L
Sample 9	120 µg/L	µg/L
Sample 10	25 µg/L	µg/L
Sample 11	13 µg/L	µg/L
Sample 12	12 µg/L	µg/L
Fully-flushed Sample	<2.0 µg/L	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
Water Quality Manager
Milwaukee Water Works
(414) 286-2226
lon.couillard@milwaukee.gov

Milwaukee Water Works

58

WATER SAMPLE TEST RESULTS FOR LEAD

Address: Ex. 6 - Personal Privacy
 Date of Report: 6/1/2016
 Type of work: Owner's Leak Repaired
 Date work performed: 4/20/2016

	Samples Collected 1 Days After Work Was Performed	Samples Collected 1 Month After Work Was Performed	Samples Collected 2 Months After Work Was Performed
	Date Sample Collected: 4/21/16	Date Sample Collected: 5/26/16	Date Sample Collected:
Sample 1	Not detected	2.2 µg/L	µg/L
Sample 2	Not detected	4.1 µg/L	µg/L
Sample 3	Not detected	5.6 µg/L	µg/L
Sample 4	Not detected	5.8 µg/L	µg/L
Sample 5	Not detected	4.2 µg/L	µg/L
Sample 6	Not detected	4.1 µg/L	µg/L
Sample 7	Not detected	4.5 µg/L	µg/L
Sample 8	Not detected	4.1 µg/L	µg/L
Sample 9	Not detected	Not detected	µg/L
Sample 10	Not detected	Not detected	µg/L
Sample 11	Not detected	Not detected	µg/L
Sample 12	Not detected	Not detected	µg/L
Fully-flushed Sample	Not detected	Not detected	µg/L

Not detected = less than 2.0 µg/L = less than 2.0 micrograms per Liter = less than 2.0 parts per billion

Lon Couillard
 Water Quality Manager
 Milwaukee Water Works
 (414) 286-2226
lon.couillard@milwaukee.gov